

**Boil Water Notice Rescinded**  
**February 25, 2021**

On February 17, 2021, the Texas Commission on Environmental Quality required the **City of River Oaks public water system identification number 2200069** to issue a Boil Water Notice to inform customers, individuals, or employees that due to conditions which occurred recently in the public water system, the water from this public water system was required to be boiled prior to use for drinking water or human consumption purposes.

The public water system has taken the necessary corrective actions to restore the quality of the water distributed by this public water system used for drinking water or human consumption purposes and has provided TCEQ with laboratory test results that indicate that the water no longer requires boiling prior to use as of **February 25, 2021**.

If you have questions concerning this matter, you may contact Public Works Director, Gordon Smith at 817-626-5421 Extension 322 or Marvin Gregory, City Manager at 817-626-5421 Extension 324 located in the City Hall complex at 4900 River Oaks Blvd, River Oaks, Texas, or Chief Water Plant Operator, John Paul Jones at 817-626-6454 located in the River Oaks Water Plant at 1900 Nancy Lane, River Oaks, Texas.

*Para asistencia en español, favor de llamar a Maria Tueme al tel 817-626-5421, extension 332.*

**Actions Taken to address the boil water notice:** Water System Distribution Pressures dropped below 20 pounds per square inch on February 17, 2021 in that the system could not provide adequate supply in order for us to meet our water system supply demands resulting in low system pressures and the immediate requirement to issue a boil water notice prior to use for drinking water or human consumption purposes.

Through our emergency water connection with the City of Fort Worth we were able to bring our system back to its normal operating pressures. We had routine bacteriological samples taken on February 24, 2021 in accordance to TCEQ requirements and the laboratory returned notice that all samples passed and **therefore, we are now approved to rescind the boil water notice effective this date, February 25, 2021 and that water from this water system is no longer required to be boiled prior to use for drinking water or human consumption purposes.**

CITY OF RIVER OAKS WATER DEPARTMENT